

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

## Thyracont Vacuum Instruments GmbH

Max-Emanuel-Strasse 10, 94036 Passau, Germany

the Certificate No: **Z12328** for the PROFINET IO Device:

Model Name: Thyracont Smartline VSP  
 Revision: SW/FW: V5.4.0; HW: 3  
 Identnumber: 0x039F; 0x003C  
 GSD: GSDML-V2.42-Thyracont-VSP-20230206.xml  
 DAP: DAP, 0x00003021

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> PNIO_Version	V2.42
<input checked="" type="checkbox"/> Conformance Class	B
<input checked="" type="checkbox"/> Optional Features	Legacy, FSU, MRP
<input checked="" type="checkbox"/> Netload Class	III
<input checked="" type="checkbox"/> PNIO_Tester_Version	Version V2.43.1
<input checked="" type="checkbox"/> Tester	SIEMENS AG, Fürth, Germany, PN754-1 plus Manufacturer Declaration

This certificate is granted according to the document:

“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by **February 17, 2026** the certificate is valid for life.

Karlsruhe, April 19, 2023



(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)




(Frank Moritz)