

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Phoenix Contact GmbH & Co. KG

Flachmarktstr. 8, 32825 Blomberg, Germany

the Certificate No: **Z12275** for the PROFINET IO Device:

Model Name: FL Switch 2206-2SFX PN
 Revision: SW/FW: V2.60.0; HW: 00
 Identnumber: 0x00B0; 0x0143
 GSD: GSDML-V2.32-PhoenixContact-FL-SWITCH-2000-20180224.xml
 DAP: DAP 5, FL SWITCH 2206-2SFX PN – FW 2.60, 0x00000300

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> PNIO_Version	V2.32
<input checked="" type="checkbox"/> Conformance Class	B
<input checked="" type="checkbox"/> Optional Features	MRP-Client, MRP-Master, Legacy, Device_Access
<input checked="" type="checkbox"/> Netload Class	II
<input checked="" type="checkbox"/> PNIO_Tester_Version	V2.34.0
<input checked="" type="checkbox"/> Tester	Phoenix Testlab GmbH, Blomberg, Germany, PNE180442E01

This certificate is granted according to the document:

“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by **July 19, 2021** the certificate is valid for life.

Karlsruhe, July 30, 2018


Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)



(Dr. Jörg Hähnliche)