

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Flowserve Corporation

5114 Woodall Road, Lynchburg, Virginia 24502, USA

the Certificate No: **Z00925** for the PROFIBUS Device:

Model Name: Accutronix MX
 Revision: -; SW/FW: 2.00; HW: 2.12
 GSD: FLSV07A1.gsd, File Version 2.12
 PA139710.gsd

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	DP-V0	MS0, Fail_Safe
<input checked="" type="checkbox"/>	DP-V1	MS2
<input checked="" type="checkbox"/>	Profile	PA Devices V 3.0
<input checked="" type="checkbox"/>	Physical Layer	MBP

Test Report Number: itm 616 PA 01/01 and PCN058-PAS-01
 Authorized Test Laboratory: itm, Munich, Germany and
 PROCENTEC, Wateringen, The Netherlands

The tests were executed in accordance with the following documents:
 "Test Specifications for PROFIBUS DP Slaves, Version 2.0 from February 2000" and
 "Test Specifications for field devices in accordance with "PROFIBUS PA Profile for Process Control Devices, Version 3.0", Version 3.1 from April 2000".

This certificate is granted according to the document:
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **May 10, 2023** the certificate is valid for life.


Karlsruhe, November 28, 2019



(Official in Charge)



Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)



(Dr. Jörg Hähniche)