

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

## SICK AG

Erwin-Sick-Str. 1, 79183 Waldkirch, Germany

the Certificate No: **Z10153** for the PROFINET IO Device:

Model Name: S3000  
 Revision: 0; SW/FW: V1.11.0; HW: 0  
 GSD: GSDML-V2.33-SICK-S3000-20180801.xml  
 Identnumber: 0x0101; 0x2001  
 DAP: DIM 1: S3000, 0x00000001

This certificate confirms that the product has successfully passed the certification tests with the following PROFINET scope:

<input checked="" type="checkbox"/> Hardware	Auto_Negotiation, Auto_Polarity, Auto_Crossover
<input checked="" type="checkbox"/> Conformance Class B	RT_CLASS_1, RTA, LLDP, SNMP, MIB-II, LLDP-MIB

Test Report Number: PN181-2  
 Authorized Test Laboratory: Siemens AG, Fürth, Germany

The tests were executed in accordance with the following documents:  
 "Test Specifications for PROFINET IO devices, Version 2.2.4 from December 2010",  
 "Test Cases for PN-Tester for PROFINET IO devices, Version 2.2.4.16.21".

This certificate is granted according to the document:  
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **April 25, 2025** the certificate is valid for life.

Karlsruhe, April 26, 2022

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)




(Dr. Jörg Hähnicke)