

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

**ProSoft Technology, Inc.**

5201 Truxtun Ave, 93309 Bakersfield, CA, USA

the Certificate No: **Z10804** for the PROFINET IO Device:

Model Name: PLX31-EIP-PND  
 Revision: 1; SW/FW: V 1.03.001; HW: 1  
 Identnumber: 0x0175; 0x8201  
 GSD: GSDML-V2.3-ProSoft-PLX31-EIP-PNDevice-V3.10-20171113.XML  
 DAP: DAP DIM 1,0x80000000

This certificate confirms that the product has successfully passed the certification tests with the following PROFINET scope:

<input checked="" type="checkbox"/> Hardware	Auto_Negotiation, Auto_Polarity, Auto_Crossover
<input checked="" type="checkbox"/> Conformance Class A	RT_CLASS_1, RT_CLASS_2, RTA, LLDP


Test Report Number: PN139-6  
 Authorized Test Laboratory: PROFI Interface Center, Johnson City, USA

The tests were executed in accordance with the following documents:  
 "Test Specifications for PROFINET IO devices, Version 2.2.4 from December 2010" and  
 "Test Cases for PN-Tester for PROFINET IO devices, Version 2.2.4.16.21".

This certificate is granted according to the document:  
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **April 27, 2021** the certificate is valid for life.

Karlsruhe, December 04, 2017



(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)




(Dr. Jörg Hähnliche)