

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

**Hilscher Gesellschaft für Systemautomation mbH**  
**Rheinstr. 15, 65795 Hattersheim, Germany**

the Certificate No: **Z10839** for the PROFINET IO Device:

**Model Name: COMX 51XX-RE/PNS**  
**Revision: SW/FW: V3.5.43; HW: 2**  
**Identnumber: 0x011E; 0x0117**  
**GSD: GSDML-V2.31-HILSCHER-COMX 51XX-RE PNS-20140430.XML**  
**DAP: DIM 24: COMX 51XX-RE/PNS V3.5.35 - V3.5.x, 0x00002081**

This certificate confirms that the product has successfully passed the certification tests with the following scope:


<input checked="" type="checkbox"/>	PNIO_Version	V2.31
<input checked="" type="checkbox"/>	Conformance Class	C Optional Features: Legacy, FSU, MRP, IRT
<input checked="" type="checkbox"/>	Netload Class	III
<input checked="" type="checkbox"/>	PNIO_Tester_Version	V2.3.5
<input checked="" type="checkbox"/>	Tester	SIEMENS AG, Fürth, Germany, PN297-1, IRT070-1

This certificate is granted according to the document:  
 "Framework for testing and certification of PROFIBUS and PROFINET products".  
 For all products that are placed in circulation by July 24, 2017 the certificate is valid for.




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)

(K.-P. Lindner)